

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

MONITORING AND REPORTING PROGRAM NO. 00-094 (REVISION NO. 1)
FOR
SALTON COMMUNITY SERVICES DISTRICT, OWNER/OPERATOR
SALTON CITY WASTEWATER TREATMENT PLANT
Salton City - Imperial County

Location of Discharge: SE ¼ of Section 21 and SW ¼ of Section 22 T10S, R10E, SBB&M

MONITORING

The collection, preservation and holding times of all samples shall be in accordance with U.S. Environmental Protection Agency approved procedures. Unless otherwise approved by the Regional Board's Executive Officer, all analyses shall be conducted by a laboratory certified for such analysis by the State Department of Health Services. All analyses shall be conducted in accordance with the latest edition of "Guidelines Establishing Test Procedures for Analysis of Pollutants" (40 CFR 136), promulgated by the United States Environmental Protection Agency.

Samples shall be collected at the location specified in the Permit. If no location is specified, sampling shall be conducted at the most representative sampling point available.

If the facility is not in operation, or there is no discharge during a required reporting period, the discharger shall forward a letter to the Regional Board indicating that there has been no activity during the required reporting period.

INFLUENT MONITORING

Influent flow monitoring shall commence following the installation of an influent meter.

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Flow (Total Plant Effluent)	MGD ¹	Flow Measurement	Daily ²

EFFLUENT MONITORING

<u>Constituents</u>	<u>Units</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
pH	pH units	Grab	Monthly
Total Dissolved Solids	mg/L	Grab	Monthly
Volatile Organic Compounds ³	µg/L ⁴	Grab	Annual
Nitrates as Nitrogen (N)	mg/L	Grab	Monthly
		Type of	Sampling

¹ Million Gallons-Per-Day

² Reported for each day with average monthly flow calculated

³ Analysis of Volatile Organic Compounds is to be accomplished using the USEPA test methods 601 and 602 or 624.

⁴ µg/L = microgram-per-liter

<u>Constituents</u>	<u>Units</u>	<u>Sample</u>	<u>Frequency</u>
Nitrites as N	mg/L	Grab	Monthly
Ammonia Nitrogen as N	mg/L	Grab	Monthly
Total Nitrogen as N	mg/L	Grab	Monthly
Total Phosphate as Phosphorus (P)	mg/L	Grab	Monthly
Orthophosphate as P	mg/L	Grab	Monthly

WATER SUPPLY TO THE COMMUNITY

The domestic water supply in the area of the facility shall be sampled for the following constituent:

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Total Dissolved Solids	mg/L	Grab	Monthly

OPERATION AND MAINTENANCE

The discharger shall report the following:

<u>Activity</u>	<u>Reporting</u>
To inspect and document any operation/maintenance problems by inspecting each unit process. In addition, calibration of flow meters and equipment shall be performed in a timely manner and documented.	Annually

SLUDGE MONITORING

The discharger shall report annually on the quantity, location and method of disposal of all sludge and similar solid materials being produced at the wastewater treatment plant facility.

The sludge that is generated at the treatment facility shall be sampled and analyzed for the following:

<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Arsenic	mg/kg ⁵	Grab	Annually
Cadmium	mg/kg	Grab	Annually
Copper	mg/kg	Grab	Annually
Lead	mg/kg	Grab	Annually
Mercury	mg/kg	Grab	Annually
<u>Constituent</u>	<u>Unit</u>	<u>Type of Sample</u>	<u>Sampling Frequency</u>
Molybdenum	mg/kg	Grab	Annually

⁵ Milligrams per Kilogram

Nickel	mg/kg	Grab	Annually
Selenium	mg/kg	Grab	Annually
Zinc	mg/kg	Grab	Annually
Fecal Coliform	MPN ⁶ /gram	Grab	Annually

REPORTING

1. The discharger shall arrange the data in tabular form so that the specified information is readily discernible. The data shall be summarized in such a manner as to clearly illustrate whether the facility is operating in compliance with waste discharge requirements.
2. Records of monitoring information shall include:
 - a. The date, exact place, and time of sampling or measurement(s);
 - b. The individual(s) who performed the sampling or measurement(s);
 - c. The date(s) analyses were performed;
 - d. The individual(s) who performed the analyses;
 - e. The analytical techniques or method used; and
 - f. The results of such analyses.
3. The results of any analysis performed more frequently than required using test procedures and locations specified in this Monitoring and Reporting Program shall be reported to the Regional Board.
4. Monitoring reports shall be certified under penalty of perjury to be true and correct, and shall contain the required information at the frequency designated in this monitoring report.
5. Each report shall contain the following statement:

"I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of a fine and imprisonment for knowing violations."
6. A duly authorized representative of the discharger may sign the documents if:
 - a. The authorization is made in writing by the person described above;
 - b. The authorization specified an individual or person having responsibility for the overall operation of the regulated disposal system; and
 - c. The written authorization is submitted to the Regional Board's Executive Officer.
7. Reporting of any failure in the waste disposal system shall be as described in Provision No. 11.
8. Daily, semi-weekly and monthly monitoring reports shall be submitted to the Regional Board by the 15th day of the following month. Quarterly monitoring reports shall be submitted to the Regional Board by January 15, April 15, July 15, and October 15, of each year. Annual monitoring reports shall be submitted to the Regional Board by January 15 of each year.

⁶ Most Probable Number

9. Submit monitoring reports to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-720 Fred Waring Drive, Suite 100
Palm Desert, CA 92260

Ordered by: original signed by/
Executive Officer

September 15, 2000
Date